



NEMA FRAME	M	R	U1	U2	CPLG. SIZE	HA	HB	HD MAX D=5.25	HE	HF	HG MAX	HH	HL	HP	HT MIN	BASE PLATE PART NO.
143T/145T	3.50	1.75	7/8	7/8	6SC	15	38	8.65	6.0	35.5	3.4	0	4.5	1.25	3.5	3519-050
182T/184T	4.50	0.75	1-1/8	7/8	6SC	15	38	8.65	6.0	35.5	3.4	0	4.5	1.25	3.5	3519-050
213T/215T	5.25	0	1-3/8	7/8	6SC	15	48	8.65	6.0	35.5	3.4	0	4.5	1.25	3.5	3520-050
254T/256T	6.25	0	1-5/8	7/8	7SC	15	48	9.65	6.0	35.5	3.4	1	4.5	1.25	3.5	3520-050

NOTES: (1) MOTOR SHOULD NOT EXTEND BEYOND BASE.  
 (2) MECHANICAL COUPLING IS WOODS SURE-FLEX, TYPE SC.  
 (3) ADD 0.31 INCHES TO "HD" DIMENSION IF THERMAL INSULATOR PADS ARE USED.

# LIQUIFLO EQUIPMENT CO.

443 NDRTH AVENUE, GARWOOD, NJ 07027

# ENDURA SERIES CENTRIFUGAL PUMP ANSI GROUP I, LONG-COUPLED, BASE ASSEMBLED