



NEMA FRAME	M	R		HA	HB	HD MAX		HE	HF	HG MAX	HH		HL	HP	BASE PLATE PART NO.
		D=8.25	D=10			D=8.25	D=10				D=8.25	D=10			
182TC/184TC	4.50	3.75	5.50	18	64	12.25	14	7.5	61.5	4	0	0	4.5	1.25	3528-050
213TC/215TC	5.25	3	4.75	18	64	12.25	14	7.5	61.5	4	0	0	4.5	1.25	3528-050
254TC/256TC	6.25	2	3.75	18	64	12.25	14	7.5	61.5	4	0	0	4.5	1.25	3528-050
284TC/286TC	7	1.25	3	18	64	12.25	14	7.5	61.5	4	0	0	4.5	1.25	3528-050
324TC/326TC	8	0.25	2	18	64	12.25	14	7.5	61.5	4	0	0	4.5	1.25	3528-050
364TC/365TC	9	0	1	18	64	13	14	7.5	61.5	4	0.75	0	4.5	1.25	3528-050

NOTES: (1) MOTOR SHOULD NOT EXTEND BEYOND BASE.  
 (2) ADD 0.31 INCHES TO "HD" DIMENSION IF THERMAL INSULATOR PADS ARE USED.

# LIQUIFLO EQUIPMENT CO.

443 NORTH AVENUE, GARWOOD, NJ 07027

# ENDURA SERIES CENTRIFUGAL PUMP

ANSI GROUP II, CLOSE-COUPLED, BASE ASSEMBLED